

TYPE EXAMINATION CERTIFICATE FOR LIFTCOMPONENTS

Issued by Liftinstituut B.V.

Certificate no. : NL19-400-1002-284-02 Revision nr.: -

Description of the product : Fire resistant two panels side opening lift landing door

Trademark, Type : Cibes, Landing door EI-60

Name and address of the manufacturer : Cibes Lift AB
Utmarksvägen 13
SE 802 91 GÄVLE
Sweden

Name and address of the certificate holder : Cibes Lift AB
Utmarksvägen 13
SE 802 91 GÄVLE
Sweden

Certificate issued on the following requirements : Lifts Directive 2014/33/EU

Certificate based on the following standard : EN 81-58:2018

Test laboratory : Eurofins Expert Services Oy
Kivimiehentie 4
FI-02150 Espoo
Finland

Date and number of the laboratory report : October 18, 2019
TEST REPORT No EUFI29-19004072-T2-01

Date of type examination : December 2019

Classification : The performance criteria of the EN 81-58 covered are:

	E	EI	EW
Landing door EI-60	60	60	60


Additional document with this certificate : Annex belonging to the type examination certificate no.: NL19-400-1002-284-02


Additional remarks : None

Conclusion : The lift landing door EI-60 meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2018, in particular for the classification indicated above

Amsterdam

Date : 19-12-2019
Valid until : 19-12-2024


ing. P.J. Peeters
Manager Certification


Certification decision by